



February 11, 2004

Roy Conner
4306 Saltwater Boulevard
Tampa, Florida 33615

RE: STORM SYSTEM

Upon my visual inspection and review of the video inspection tape of the storm system, I found 1 and 6 to be in roughly the same condition as was video taped by the County. The rest of the pipes are in very good condition.

It is my suggestion that a storm fund be started to slip-line section 1 and 6 in approximately 1.5 to 2 years. The asphalt over the storm pipes appears to be in good condition. The lines look good with no debris build up.

It is also my suggest that another visual inspection be performed in approximately 8 months.

If you should have any questions or concerns regarding this matter, please contact me at (813) 677-7655.

Respectfully yours,

Jerry Lemanski, President
BAY AREA ENVIRONMENTAL SERVICES, INC.

